

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7258-1574:109 Page 1 of 1

**CATEGORY:** Combination Ionization/Photoelectric Smoke Detector

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Fairfield, NJ 07004  
Contact: \*Ron Dalton (310) 725-2972 Fax (310) 725-2942

**DESIGN:** Model ADT-IPHS combination ionization/photoelectric smoke detector. Unit has built in heat sensor. Refer to listee's data sheet for detailed model descriptions and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as an combination ionization/photoelectric smoke detector for use with listee's separately listed base (CSFM Listing No. 7300-1574:106) and compatible fire alarm control units.

**NOTE:** NOT INTENDED TO BE USED IN LIEU OF REQUIRED HEAT DETECTORS.

**XLF:** 7258-1591:123 Formerly 7258-1388:183

\*Rev. 07-01-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 1, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager